

ADDENDUM NO. 3


**CITY OF HIALEAH
FIRE STATION NO.3-ROOFING & LWIC
HIALEAH, FLORIDA**

FEBRUARY 20, 2013

TO ALL CONCERNED

The original Contract Documents, for the Project entitled **CITY OF HIALEAH – FIRE STATION NO. 3-ROOFING AND LWIC BID NO. 2012/13-2000-00-026** is hereby amended as noted in this **Addendum No. 3**.

This **Addendum No. 3** consists of **1** Typed Pages, **0** Sketches, **0** Attachments and **0** Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: February 20, 2013
Carlos Lopez-Acting Purchasing Director

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 3** shall be acknowledged in the space provided on the **ADDENDUM RECEIPT FORM (ARF)** (copy attached) now a part of the Contract Documents faxed immediately to City of Hialeah @ (305) 883-5871, and submitted with sealed bids.

IN THE CONTRACT DOCUMENTS:

Response to RFI from A-1 Property Services dated 2/19/13:

1. What is the term of the NDL warranty 10,12,15,20 years by manufacture? **20 years**
2. There are multiple types of deck. When not insulated its LWC will we have to remove LWC to replace with NEW LWC? **Core samples to be performed by roofing contractor to determine if existing LWC can be reused. If LWC needs to be replaced, it will be handled as a change in scope.**
3. ON LWC deck will insulation be required? **a 1" layer of existing insulation to remain or replaced if damaged.**
4. Will LWC be removed and replaced with ISO board? **ISO boards to be used to obtain roof slopes when required.**
5. Plans only show insulated deck application **Refer to NOA**
6. Can you confirm project will take R-20 MIN **yes.**
7. Will Hatch be Replaced? **Hatch is not called to be replaced.**
8. Exhaust fans will have to be raised is this part of the roofing contractor? **Yes**
9. Copping's on lower roof are not part of the roofing system (is this excluded for the base bid)? **Yes**

ROOFING AND LIGHTWEIGHT INSULATING CONCRETE - 2012/13-2000-00-026

ADDENDUM RECEIPT FORM

CITY OF HIALEAH

**FIRE STATION NO. 3
ROOFING AND LWIC**

ADDENDUM NO. 3

CONTRACTOR'S NAME _____

ADDRESS _____

PHONE NO. _____ **FAX NO.** _____

CONTACT NAME _____ **SIGNATURE** _____

THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY of HIALEAH @ (305) 883-5871.

ADDENDUM

SIGNATURE

DATE

3

ROOFING AND LIGHTWEIGHT INSULATING CONCRETE - 2012/13-2000-00-026

ARF